

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0021903 Discharge Number: _____

Facility: Waste Water Treatment Plant _____

Address: 545 Bowden Rd _____

City: Wynne State: AR Zip: 72396 _____

Contact: Blake Marotti Phone: 870-238-2751 _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
7-20-22	Fecal		>2420	2000

We feel this problem was due to:

~~a contaminated sample bottle or a lab error.~~

We plan on correcting the problem in this manner:

~~Resamples were taken and split and sent to two different labs the following week to compare and they both came back with a fecal count that was low and comparable to normal for us. The labs that the samples were sent to are Arkansas Analytical in Little Rock and Waypoint Analytical in Memphis.~~

Time estimated that it will take to correct problem:

~~We believe that the problem was a rare occurrence and that the problem has already been resolved~~

Sincerely,



Submitted By:

Date

08/08/2022

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)