

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0021903 Discharge Number: Outfall 001
 Facility: WWTP
 Address: 545 Bowden Rd.
 City: Wynne State: AR Zip: 72396
 Contact: Blake Marotti Phone: (870) 238-2751

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
8-18-21	Fecal Coliform Bacteria (FCB)		>2420 MPN/100ml	2000 colonies/100ml (7 day average)

We feel this problem was due to:

~~an lab anomaly, due to nothing out of the ordinary happening in the plant at the time. The U.V. lights were on and operating correctly and our flow was normal.~~

We plan on correcting the problem in this manner:

~~The Fecal sample from the next week, 8/25/21, was only 190 which is around what we normally expect to see~~

Time estimated that it will take to correct problem:

~~We believe that the problem has already been resolved.~~

Sincerely,



Submitted By:

09/07/2021
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)