

WYNNE WATER UTILITIES
WYNNE, ARKANSAS
72396

Date: September 8, 2016

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Dr.
North Little Rock, Arkansas 72118-5317

Re: NPDES Permit No: AR0021903

Client: Wynne, City Of
Address: 121 Merriman Ave.
City: Wynne
State: AR
Zip: 72396
Phone: 870-238-2751
Contact: Don M. O'Neal, Manager


Date Of	Parameter	D.O.	Permit
Non-Compliance	Exceeded	Reading	Inst. Min.
August 3, 2016	Effluent D.O.	6.4	7.0

We feel this problem was due to:

The night of August 2nd we experienced a short power outage. The backup battery for the diffusers was dead because of an oversight in the amount of time that it had been since it had been changed, this caused the diffusers to run for a shorter time then intended.

To correct this problem we are keeping better track of the maintenance of our timers and the times when the battery backups are changed and checking the timers to insure that they are set properly.

Yours Very Truly,



Authorized Signature

WYNNE WATER UTILITIES

*121 East Merriman
Wynne, Arkansas 72396*

MEMPHIS
TN 380
14 SEP '16
PM 5 L



Ark. Dept. of Environmental Quality
NPDES Enforcement Section
5301 Northshore Dr.
North Little Rock, AR 72118-5317

RETURN SERVICE REQUESTED

72118-531799

