



WYNNE WATER UTILITIES  
WYNNE, ARKANSAS  
72396

Date: March 19, 2014

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Dr.  
North Little Rock, Arkansas 72118-5317

Re: NPDES Permit No: AR0021903 Violation

Client: Wynne, City Of  
Address: 121 Merriman Ave.  
City: Wynne  
State: AR  
Zip: 72396  
Phone: 870-238-2751  
Contact: Don M. O'Neal, Manager


Date Of Violation	Parameter Exceeded	Concentration Loading	Permit Limits
February 5, 2014	TSS MG/L 7 Day Avg.	31.380 MG/L	22.5 MG/L



We feel this problem was due to:

Our mixed liquor concentration usually is between 3500 and 4000. During this time due to the freezing temperatures and ice on our equipment for several weeks we were unable to waste. Our mixed liquor concentration was averaging above 6000 causing more solids than usual to inter the effluent.

To correct this problem in the future we need to plan ahead and lower our mixed liquor concentration as the weather predicts.

Yours Very Truly,


  
\_\_\_\_\_  
Authorized Signature



**WYNNE WATER UTILITIES**

121 E. MERRIMAN  
WYNNE, AR 72396

(870) 238-2751  
"Water is Life"



**TO:**

**Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Dr.  
North Little Rock, Arkansas 72118-5317**