



WYNNE WATER UTILITIES

"Water is Life"



November 6, 2015

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Dr.
North Little Rock, AR 72118-5317

Re: NPDES Permit No. AR0021903 - Potential for Violation

Client: Wynne, City of
Address: 121 Merriman Ave. E
City: Wynne
State: AR
Zip: 72396
Phone: 870-238-2751
Contact: Don M. O'Neal, Manager

Date of Non-Compliance	Parameter Exceeded	7-Day Geo Concentration Loading	Permit Limits
October 20, 2015	Fecal Coliform	3,999 # 100 ml	2,000#100ml

We feel this problem was caused by:

Due to a miscommunication within the plant personnel the UV System was scheduled for cleaning but was delayed. This delay resulted in an increase in fecal coliform as indicated herein.

The manpower shortage has been corrected and it is anticipated that this issue will not repeat itself.

If you have any concerns regarding this please contact me at 870-238-2751.

Respectfully,

Don M. O'Neal, General Manager
Wynne Water Utilities

DMO/pm

CC: Shannon McKnight, Plant Manager
Harrell Williams, Environmental Compliance

WYNNE WATER UTILITIES

*121 East Merriman
Wynne, Arkansas 72396*



02 1P **\$ 000.48⁵**
0001851182 NOV 06 2015
MAILED FROM ZIP CODE 72396

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Dr.
North Little Rock, AR 72118-5317

RETURN SERVICE REQUESTED

721 18531 799

