

March 4, 2021

Honorable Frank Fogleman Mayor, City of Marion P.O. Box 717 Marion, AR 72364

RE: NPDES Permit Number AR0021971, AFIN 18-00110

Permitted Effluent Limitation Violations

Dear Mayor Fogleman,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

email: jshempert.waterdept@yahoo.com

The facility has reported 11 violations of Part I, Section A of NPDES Permit No. AR0021971 during the review period. DEQ requires the City of Marion to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0664, or you may e-mail me at Sarah.Pierce@adeq.state.ar.us.

Sincerely,

Sarah Pierce

Enforcement Analyst

Office of Water Quality, Enforcement Branch

12/31/2020	002-A	BOD, 5-day, 20 deg. C, MO AVG, mg/L	30	35.5	18%	E90
11/30/2020	002-A	BOD, 5-day, 20 deg. C, MO AVG, mg/L	30	32.63	9%	E90
05/31/2020	002-A	BOD, 5-day, 20 deg. C, MO AVG, mg/L	30	40.44	35%	E90
04/30/2020	002-A	BOD, 5-day, 20 deg. C, MO AVG, mg/L	30	46.13	54%	E90
04/30/2020	002-A	BOD, 5-day, 20 deg. C, 7 DA AVG, mg/L	45	59	31%	E90
11/30/2019	002-A	BOD, 5-day, 20 deg. C, MO AVG, mg/L	30	33.38	11%	E90
10/31/2019	002-A	BOD, 5-day, 20 deg. C, MO AVG, mg/L	30	49.9	66%	E90
10/31/2019	002-A	BOD, 5-day, 20 deg. C, 7 DA AVG, mg/L	45	62	38%	E90
09/30/2019	002-A	BOD, 5-day, 20 deg. C, 7 DA AVG, mg/L	45	57	27%	E90
07/31/2019	002-A	BOD, 5-day, 20 deg. C, MO AVG, mg/L	30	30.89	3%	E90
05/31/2019	002-A	BOD, 5-day, 20 deg. C, MO AVG, mg/L	30	33.75	13%	E90