Marion Water Department

MAYOR FRANK A FOGLEMAN

WATER UTILITIES MANAGER
JIM SHEMPERT

31 MILITARY ROAD P.O. BOX 814 MARION, ARKANSAS 72364 PHONE: 870-739-3073 FAX: 870-739-5415

WATER & SEWER COMMITTEE

JIM SPENCE, CHAIRMAN KELLY O'NEAL CLIFF WOOD

February 13, 2014

Arkansas Department of Environmental Quality NPDES Enforcement Section 5301 Northshore Drive

January 2014

Non-Compliance Letter:

We have been pumping with a relift pump from our 3rd cell of our lagoons into our Rock Beds to help lower our pond levels. This pumping we think is causing us to exceed our permit limits on TSS, AMMONIA NITROGEN AND BOD. We hope to have our pond levels back to normal soon allowing us to terminate this extra pumping.

Jim Shempert

Water Utilities Manager

Sanitary Sewer Overflow Monthly Report

Facility Name: Marion, City of Permit Number: AR0021971 Reporting Period (Month/Year): JAWUARY 2014


E No Sanitary Sewer Overflows This Monitoring Period

Cause(s) of SSO		Summary Report Code Descriptions SSO Impact Action(c) Telep						
		330 Impact,	Action(s) Taken	Ultimate Discharge Location				
CO-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental		CR-Creek/Stream/River (please specify				
E-Equipment Failure HC-Hydro Clean	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup					
	LF-Line Failure/Break	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DI-Ditch DR-Drop Inlet				
R-Rainfall	RG-Roots & Grease		TID II. ID III.					
RO-Roots	V-Vandalism		HR-Hand Rodded	GR-Ground Surface				
			EN-Referred to Engineering	PA-Paved Area				
	<u> </u>		PN-Public Notification	CB-Contained in Building				

Location	Manhole #	Start Date of SSO	End Date of	Estimated Volume	Cause of SSO	Environmental	Action (s) Taken	Ultimate Discharg
			SSO	(in gallons)		Impact	to Address SSO	Ultimate Discharg Location
<u> </u>								
	·							
								·
	· .							

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

31 MICITARY RD. MARION, AR. 7236 4



ADEQ NPDES ENFORCEMENTS ECTION 530 I NORTH SHORE DRIVE NORTH LITTLE ROCK, AR. 72118-5317