

Sanitary Sewer Overflow (SSO) Monthly Report

Monitoring Period (Month/Year): 02 / 2025

☒ No Sanitary Sewer Overflows This Monitoring Period

REPORT CODE DESCRIPTIONS					
Cause(s) of SSO		Environmental Impact	Action(s) Taken		Ultimate Discharge Location
C - Construction	D - Debris	EFK - Evidence of Fish Kill	EC - Environmental Cleanup	JV - Jet Vac	GR - Ground
EF - Equipment Failure	G - Grease	OEHC - Evidence of Human Contact	HC - Hydro Cleaned	SL - Spread Lime	CR - Creek / Stream / River (specify)
LF - Line Failure	R - Rainfall (1&1)	OEEI - Evidence of Environmental Impact	HR - Hand Rodded	DD - Disinfected and Deodorized	DI - Ditch
PF - Power Failure	RO - Roots	NEAH - No Evidence of Adverse Health or Environmental Impact	MR - Machine Rodded	GP - Used Generator to Power Equipment	DR - Drop Inlet
V - Vandalism			PN - Public Notification		PA - Paved Area
			EN - Referred to Engineering		CB - Contained in Building

[illegible]

Handwritten signature: *[Signature]*

Signature of Cognizant or Ranking Official

Date _____

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Mail together with DMR submission **NO LATER THAN THE 25th OF THE MONTH FOLLOWING THE MONITORING PERIOD** to:
ADEQ Office of Water Quality ♦ 5301 Northshore Drive ♦ North Little Rock, AR 72118