## **NON-COMPLIANCE REPORT**

Arkansas Department of Energy & Environment Division of Environmental Quality Office of Water Quality, Enforcement Section 5301 Northshore Drive, North Little Rock, AR 72118

RE: Permit No:AR0022004	Discharge Number: 001		
Facility: Huntsville Wastewater Facility			
Address: 30187 Hwy 23 Noth			
City: Huntsville	State: AR	Zip: 72740	
Contact: Sean Davis	Phone:479-738-6929		

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
1/11/2024	CBOD 5-Day		30.9 mg/L	15 mg/L
1/11/2024	Total Suspended Solids		37.9 mg/L	22.5 mg/L
01/11/2024	CBOD monthly average		13 mg/L	10 mg/L
01/11/2024	TSS monthly average		16.3 mg/L	15 mg/L

We feel this problem was due to:

Industrial loading from the Huntsville Butterball Plant.

## We plan on correcting the problem in this manner:

Due to the inconsistant influent provided by our industrial user, we are reviewing and updating our pretreatment ordinance, with the possibility of more strigent limits for the industry.

## Time estimated that it will take to correct problem:

The incident of non-compliance has been corrected by the industry prior to the writing of this report.

Sincerely,

January 22, 2024

Submitted By:

Date

## Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)