

## AGENDA

DEQ meeting with West Memphis Utilities (WMU)

AR0022039

Thursday, December 5, 2019 at 10:00am

1. Introductions and meeting sign in sheet
2. Tim Verner gave everyone an update on the progress that has been made concerning the Corrective Action Plan.
  - a. RJN submitted their final report detailing a model with a 2-year/24-hour design
    - i. Dr. Bob Blanz asked for documentation justifying a 2 year return when the Water Quality Standard for the receiving stream is a 10 year return
  - b. He made note that the WWTF has two main issues at this point
    - i. Influent channel is undersized
    - ii. Hydraulics of the clarifier make it difficult for the system to handle all of the flow
3. Proposed CAO was discussed
  - a. A Revised Corrective Action Plan will need to be submitted
  - b. A revised penalty reduction request with dollar amount will need to be submitted
  - c. RJN will need to re-analyze their report based on the comment by Dr. Blanz above, and so WMU may need to revise their Hydraulic Improvement Report
  - d. Bryan Leamons asked about the status of the Permit Compliance Schedule concerning the TBLLs. The first report has been submitted. The second report is still due.
4. Questions
5. Follow up:
  - a. Revised penalty reduction request due **ASAP**
  - b. Revised Corrective Action Plan due **January 31, 2020**
  - c. Hydraulic Improvement Report due **January 31, 2020**
  - d. **Documentation justifying a 2 year return due January 31, 2020**
  - e. Written notification that a technical evaluation revising the current TBLLs due **December 31, 2019**