

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0022039 Discharge Number: 001

Facility: West Memphis Wastewater Facility

Address: 502 South Loop

City: West Memphis State: AR Zip: 72301

Contact: Paul Holloway Phone: 870-732-7600

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
8/2022	TSS mg/l Monthly Average	39 mg/l		30

We feel this problem was due to:

~~High BOD loading coming in causing the plant to become upset. Cloudy effluent in the clarifies. Poor settling and low D.O. levels in the aeration basins.~~


We plan on correcting the problem in this manner:

~~One of our industries, Coca Cola discharged a high BOD waste. We are working with them to reduce there BOD loading from there discharge.~~

Time estimated that it will take to correct problem:

~~We are currently meeting effluent standerds. Will continue to monitor Coca Cola to make sure we meet effluent standerds.~~

Sincerely,

 9/14/2022
Submitted By: Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)