

## NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 Office of Water Quality – Enforcement Branch  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: Permit No: AR0022039 Discharge Number: 001  
 Facility: West Memphis Wastewater Facility  
 Address: 502 South Loop  
 City: West Memphis State: AR Zip: 72301  
 Contact: Paul Holloway Phone: 870-732-7600

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
7/28/2022	Weekly Eff. TSS Mg/l		<del>76.6</del> 76.7	45
7/2022	Monthly Eff. TSS Mg/l		45.5	30
7/2022	Monthly Pounds TSS	1,731		1576
7/28/2022	Weekly Fecal GEO		<del>16155</del> 3512	400

We feel this problem was due to:

~~High BOB loading coming in causing the plant to become upset. Cloudy effluent in the clarifiers. Poor settling.~~


We plan on correcting the problem in this manner:

~~One of our industries, Coca Cola discharged high BOD waste. Having a talk with them to correct the problem.~~

Time estimated that it will take to correct problem:

~~Two weeks to re populate sludge inventory.~~

Sincerely,



8/11/2022

Submitted By:

Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 Office of Water Quality – Enforcement Branch  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: Permit No: AR0022039 Discharge Number: 001  
 Facility: West Memphis Wastewater Facility  
 Address: 502 South Loop  
 City: West Memphis State: AR Zip: 72301  
 Contact: Paul Holloway Phone: 870-732-7600

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
7/2022	Monthly Fecal GEO		<del>400</del> 458	200

We feel this problem was due to:

~~High BOB loading coming in causing the plant to become upset. Cloudy effluent in the clarifies. Poor settling.~~


We plan on correcting the problem in this manner:

~~One of our industries, Coca Cola discharged high BOD waste. Having a talk with them to corret the problem.~~

Time estimated that it will take to correct problem:

~~Two weeks to re-populate sludge inventory.~~

Sincerely,

  
 Submitted By:

8/11/2022  
 Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)