

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality – Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: AR0022039 Discharge Number: 001  
Facility: West Memphis Wastewater Treatment Plant  
Address: 502 S. Loop  
City: West Memphis State: AR Zip: 72301  
Contact: Paul Holloway Phone: 901-857-4925

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
10/2021	Weekly Average TSS		48.8	45.0
10/2021	Monthly Average TSS		40.7	30.0

We feel this problem was due to:

Toxic Load that came in in the Month of September that caused us to have violations for both months.

We plan on correcting the problem in this manner:

We re-seeded the Plant and it's back under normal operation.

Time estimated that it will take to correct problem:

It is corrected

Sincerely,



Submitted By:

Nov. 8, 2021  
Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)