

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0022039 Discharge Number: 001

Facility: West Memphis Wastewater Treatment Plant

Address: 502 South Loop

City: West Memphis State: Ar Zip: 72301

Contact: P)aul Holloway Phone: 901-857-4925

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
2	Minimum PH		<i>5.0, 5.8</i>	6.0
1	Monthly Average TSS mg/l		34.6	30
2	Weekly Average TSS mg/l		<i>44.5</i> , 54.8	45
3	Fecal, 1 Monthly and 2 Weekly		1537, 24194, 24194	200/400

We feel this problem was due to:

~~Toxic Load came in the plant causing an upset. Had to reseed the treatment plant.~~

We plan on correcting the problem in this manner:

~~Reseeded plant. all effluent numbers are back in normal range.~~

Time estimated that it will take to correct problem:

~~2 to 3 weeks. As of 10/22/2021, plant back in range.~~

Sincerely,



Submitted By:



Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)