



DIVISION OF ENVIRONMENTAL QUALITY

Sarah Huckabee Sanders
GOVERNOR

Shane E. Khoury
SECRETARY

July 25, 2024

Honorable Jonas Anderson, Mayor
City of Cave City
120 East Spring St.
Cave City, AR 72521

RE: City of Cave City
WWAC Application
AFIN: 68-00015; NPDES Permit: AR0022110

Dear Mayor Anderson:

The Department of Energy & Environment's Division of Environmental Quality (DEQ) Office of Water Quality (OWQ) has reviewed the application for the above-referenced facility and has the following comments on the application:

- A Construction Stormwater General Permit ARR150000 is required if the project disturbs one (1) acre or more of land. If the construction will disturb equal to or greater than one (1) acre and less than five (5) acres, the project is considered an automatically covered site. If the construction will disturb five (5) acres or greater, the approval of Construction Stormwater General Permit coverage from DEQ is required prior to the start of construction. Instructions for Construction Stormwater Permits, including automatic coverage, is accessible on the DEQ website at <https://www.adeq.state.ar.us/water/permits/npdes/stormwater/>.
- The Construction Stormwater General permit does not authorize any activity to be conducted in Waters of the State or Waters of the United States. Work in Waters of the State requires a short-term activity authorization (STAA) from DEQ prior to working in the wetted area of a stream or water body. A STAA is necessary for any in-stream activity that could cause an exceedance of applicable water quality standards, including, but not limited to, gravel removal, bridge or crossing repair/maintenance, bank stabilization, debris removal, culvert replacement, flood control projects, and stream relocation. Appropriate best management practices should be used during construction to ensure the protection of the water quality and prevent future impacts or impairment of the receiving waters.

We appreciate your cooperation with this pre-application process. If you have any questions or comments, contact Joe Martin, Interim Deputy Associate Director, at (501) 682-0660, or by email at: Joe.M.Martin@arkansas.gov.

Sincerely,

A handwritten signature in blue ink that reads "Joe Martin". The signature is written in a cursive, flowing style.

Joe Martin
Interim Deputy Associate Director, Office of Water Quality
Division of Environmental Quality

cc: Stacie Wassell, Associate Director, Office of Water Quality, DEQ
Richard Healey, Enforcement Branch Manager, Office of Water Quality, DEQ