

ADEQ

ARKANSAS
Department of Environmental Quality

November 22, 2019

Hon. David Rieder, Mayor
City of Clarksville
P.O. Box 1807
Clarksville, AR 72830

RE: NPDES Permit Number AR0022187, AFIN 36-00038
Permitted Effluent Limitation Violations

Dear Mayor Reider,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

The facility has reported 1 violation of Part I, Section A of NPDES Permit No. AR0022187 during the review period. A detailed list of the violations has been included with this letter. The Department expects the City of Clarksville Light and Water to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

The Department recommends that the City of Clarksville Light and Water consult with a professional engineer for the purpose of developing a corrective action plan (CAP) designed to eliminate violations of the effluent limitations of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at gavin.gray@adeq.state.ar.us.

Sincerely,



Gavin Gray
Enforcement Analyst
Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
10/31/2019	001-A	BOD, carbonaceous [5 day, 20 C], 7 DA AVG, mg/L	15	15.32	2%