

ADEQ

ARKANSAS
Department of Environmental Quality

September 5, 2018

Gregg Rainey
Clarksville Light & Water CO
P.O. Box 1807
Clarksville, AR 72830

RE: NPDES Permit Number AR0022187, AFIN 36-00038
Permitted Effluent Limitation Violations

Dear Mr. Joyner,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility for the reveals the following compliance issues:

The facility has reported 2 violations of Part I, Section A of NPDES Permit No. AR0022187 during the review period. A detailed list of the violations has been included with this letter. The Department expects that the Clarksville Light & Water CO to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at gavin.gray@adeq.state.ar.us.

Sincerely,



Gavin Gray
Enforcement Analyst
Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
07/31/2018	001-A	BOD, carbonaceous [5 day, 20 C], MO AVG, mg/L	10	12.42	24%
07/31/2018	001-A	BOD, carbonaceous [5 day, 20 C], 7 DA AVG, mg/L	15	17.64	18%

