

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022187 Discharge Number: 001

Facility: Clarksville Light & Water

Address: 1305 South Crawford

City: Clarksville State: AR Zip: 72830

Contact: Gregg Rainey Phone: 479-754-6241

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
2-29-2016	CBOD	19.92		15

We feel this problem was due to:

Shutting down 1 clarifier to change gearbox

We plan on correcting the problem in this manner:

Putting clarifier back in service

Time estimated that it will take to correct problem:


Done

Sincerely,

Gregg Rainey
Authorized Signature

2-29-2016
Date

CERTIFIED MAIL®



7015 3010 0002 0192 8928



U.S. POSTAGE >> PITNEY BOWES



ZIP 72830 \$ 007.67⁰
02 1W
0001370120 MAR. 07. 2016

CLARKSVILLE LIGHT & WATER CO.

400 WEST MAIN • P.O. BOX 1807
CLARKSVILLE, AR 72830
PHONE (479) 754-3148

To

ADEQ
5301 Northshore Drive
North Little Rock, AR 72118