

Lawrence, Myrl

From: Lawrence, Myrl
Sent: Wednesday, August 12, 2020 3:26 PM
To: 'sorman@bentonvillear.com'
Cc: 'nbusen@bentonvillear.com'
Subject: AR0022403 Bentonville Effluent Limit Violation Warning



ARKANSAS
ENERGY & ENVIRONMENT

August 12, 2020

Honorable Stephanie Orman
Mayor, City of Bentonville
117 West Central Avenue
Bentonville, AR 72712

Email: sorman@bentonvillear.com

RE: NPDES Permit Number: AR0022403, AFIN: 04-00154, City of Bentonville
Effluent Limit Violation Warning

Dear Mayor Orman,

A review of the Permit file for the above mentioned facility was conducted today for the period of January 1, 2020, through June 30, 2020. The review revealed the following compliance issues:

The facility has reported two (2) effluent limit violations of Part I, Section A of Permit No. AR0022403:

Parameter Number	Parameter	Monitoring Period End Date	Violation Code	DMR Value	% Vio	Limit Value
80082-1-0	BOD, carbonaceous [5 day, 20 C], MO AVG, lb/d	05/31/2020	E90	385.5	16%	333.6
80082-1-0	BOD, carbonaceous [5 day, 20 C], MO AVG, mg/L	05/31/2020	E90	10.2	2%	10

Non-compliance reports were received by the Division, and the corrective actions being taken as described in the submitted NCRs have been deemed an adequate response. As a reminder, any violation of your Permit may be subject to further enforcement action by this Division, pursuant to the Arkansas Water and Air Pollution Control Act.

Should you have questions or desire assistance feel free to contact the undersigned.

Kindest Regards,

Myrl V L Jr.

Myrl V Lawrence Jr | Enforcement Analyst
**Division of Environmental Quality | Office of Water Quality
Enforcement Branch**

5301 Northshore Drive, North Little Rock, AR 72118
t: 501.682.0699 | e: myrl.lawrence@adeq.state.ar.us

CC: Nancy Busen, Wastewater Supervisor, City of Bentonville, nbusen@bentonvillear.com

ARKANSAS DEPARTMENT OF ENERGY AND ENVIRONMENT