

## Sanitary Sewer Overflow Monthly Report

Facility Name: City of Bentonville

Permit # AR0022403 Reporting period April 1-30

Pictures in Water Drive/Sewer Overflows  
2021

☐ No Sanitary Sewer Overflows This Monitoring Period

### Summary Report Code Descriptions

Cause(s) of SSO		SSO Impact	Action(s) Taken	Ultimate Discharge Location
C0-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact	WO-Work Order	CR-Creek/Stream/River
Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure/Break	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
Rainfall	RG-Roots & Grease		HR-Hand Rodded	GR-Ground Surface
RO-Roots	Vandalism		EN-Referenced to Engineer PN-Public Notification	PA-Paved Area CB-Contained in Building

Location	Manhole Number	Start Date of SSO	End Date of SSO	Estimated Volume in Gallons	Cause of SSO	Environmental Impact	Action(s) Taken to Address SSO	Ultimate Discharge Location
3608 SE Riviera Rd	486-5073	4/28/2021	4/28/2021	110,000	Rainfall	NEAH	EC	CR

Nancy Busen

5-3-2021

Signature of Cognizant or Ranking Official

Date

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

# CONFIRMATION NUMBER

## 73c07a0f-1506-4ec4-ba92-8122d3e14b3f

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

### Date/Time Overflow Range

\*Date Overflow Began:

4/28/2021

\*Time:

10:00 am

Date Overflow Ended:

4/28/2021

Time:

10:00 pm

### Facility/Permit Information

\*Facility Name:

City of Bentonville

\*Permit Number:

AR0022403

### Location Information

Provide address and manhole number if numbered. Include where the overflow went into a yard, ditch, stream, storm sewer, building, or other. Be specific as possible.

The overflow occurred at 3608 SE Riviera Rd at manhole #486-5073. Bentonville had rainfall totals of 5" to 6" of rain in a short period of time. The overflow that occurred was due to the amount of I & I in our system and the downstream lift station could not keep up. Results of the situation is estimated that 110,000 gallons flowed out of manhole and entered a nearby stream. (Osage Tributary 1). Our sewer team is cleaning up what is left from the overflow this morning.

### Description of Problem (check all items that apply)

#### Type of Overflow

Manhole Overflow  Lift Station Overflow  Main Line Overflow  Service Line Overflow  Other:

#### Cause of Overflow

I & I - Rainfall  Roots  Grease  Debris  Equipment Failure

Construction  Vandalism  Power Failure  Line Failure/Break  Other:

Volume of Overflow:

110000

Impact of SSO Overflow Incident

SSO Reached Receiving Water (river,stream)

### Environmental Damage (check all items that apply)

- OEHC - Observed or Evidence of Human Contact  OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill Manhole  NEAH - No Evidence of Adverse Health/Environmental Impact

Action Taken (check all items that apply)

Short term and long-term action, including clean-up and any plans to remediate I & I.

- Machine Rodded  Jet-Vac  Hand Rodded  Used Generator to Power Pumps/Equipment
- Disinfected and Deodorized  Hydro Cleaned  Spread Lime on Affected Area  Public Notification  Other:

Reported By

"I certify" under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name:

Loran Shipman

Title:

Wastewater Collection Supervisor

Phone:

4792713140

Email a Copy of This Report to the Email Address:

[lshipman@bentonvillear.com](mailto:lshipman@bentonvillear.com)

Additional Comments: