

Sanitary Sewer Overflow Monthly Report

Pictures in Water Drive/Sewer Overflows

Facility Name: City of Bentonville

Permit # AR0022403 Reporting period July 1-31

2016

Sanitary Sewer Overflows This Monitoring Period Summary Report Code Descriptions

Cause(s) of SSO	SSO Impact	Action(s) Taken	Ultimate Discharge Location
C0-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact	WO-Work Order
Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup
HC-Hydro Clean	LF-Line Failure/Break	EFK-Evidence of Fish Kill	HC-Hydro Cleaned
Rainfall	RG-Roots & Grease		HR-Hand Rodded
RO-Roots	Vandalism	EN-Referenced to Engineer	PA-Paved Area
		PN-Public Notification	CB-Contained in Building

Location	Manhole Number	Start Date of SSO	End Date of SSO	Estimated Volume in Gallons	Cause of SSO	Environmental Impact	Action(s) Taken to Address SSO	Ultimate Discharge Location

Signature of Cognizant or Ranking Official
James Butler

Date
8-17-16

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."