

Sanitary Sewer Overflow Monthly Report

Facility Name: City of Bentonville

Permit # AR0022403 Reporting period May 1-31

2015

Sanitary Sewer Overflows This Monitoring Period Summary Report Code Descriptions

Cause(s) of SSO	SSO Impact	Action(s) Taken	Ultimate Discharge Location
C0-Construction	D-Debris	WO-Work Order	CR-Creek/Stream/River
Equipment Failure	G-Grease	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure/Break	HC-Hydro Cleaned	DR-Drop Inlet
Rainfall	RG-Roots & Grease	HR-Hand Rodded	GR-Ground Surface
RO-Roots	Vandalism	EN-Referenced to Engineer PN-Public Notification	PA-Paved Area CB-Contained in Building

Location	Manhole Number	Start Date of SSO	End Date of SSO	Estimated Volume in Gallons	Cause of SSO	Environmental Impact	Action(s) Taken to Address SSO	Ultimate Discharge Location
1706 S.E. Walton		5/8/2015	5/11/2015	1,080,000	Rainfall	Neah	EC	CR, GR
1706 S.E. Walton		5/20/2015	5/21/2015	273,000	Rainfall	Neah	EC	CR, GR
1706 S.E. Walton		5/24/2015	5/27/2015	975,000	Rainfall	Neah	EC	CR, GR
1706 S.E. Walton		5/27/2015	5/28/2015	60,000	Rainfall	Neah	EC	CR, GR
1706 S.E. Walton		5/29/2015	5/31/2015	720,000	Rainfall	Neah	EC	CR, GR

Signature of Cognizant or Ranking Official

Date

Nancy Butler

6/3/2015

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."