



**WASTEWATER DEPARTMENT
Industrial Pretreatment Division**

November 24, 2015

Ms. Jacqueline Trotta
Enforcement Analyst
Water Division / NPDES Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, Arkansas 72118-5317

RE: NPDES Permit No. AR0022403, AFIN 04-00154
Final Compliance Report
South Lift Station Renovation and Force Main Upgrade
City of Bentonville

Dear Ms. Trotta:

The City of Bentonville has completed the South Lift Station Renovation and Force Main Upgrade Project as of November 20, 2015. The project was deemed substantially complete on October 16, 2015 with all items installed. Punch list items have been corrected and the station and associated force main are fully operational. This project brings the City into compliance eliminating recurring sanitary sewer overflows associated with high flow events near the South Lift Station. Said overflows were historically reported at 1706 SE Walton Boulevard.

This project has increased the capacity of the lift station to handle additional demand and potential development as well as anticipated infiltration during significant rain events. With this project, the pump rate for one pump running increased from 900 gpm to slightly over 1500 gpm. The pump rate for two pumps operating more than doubled from an average of 950 gpm to an average of 2,100 gpm, and the three pump average increased from 975 gpm to 2,500 gpm.

Please feel free to contact me at 479-271-3161 or nbusen@bentonvillear.com if you have any questions or wish to further discuss any items.

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Respectfully,




Nancy Busen
Wastewater Utilities Manager
1901 N.E. "A" Street
Bentonville, AR 72712

Cc: Mr. Preston Newbill, City of Bentonville Water Utilities Department Manager
Mr. Mike Bender, City of Bentonville Public Works Director
Mr. Nick Batker, McClelland Consulting Engineers, Inc.
File

CERTIFIED MAIL™




City of Bentonville
Wastewater Plant
1901 N.E. A Street
Bentonville, AR 72118



7013 1090 0001 0961 5641



U.S. POSTAGE » PITNEY BOWES



ZIP 72701 \$ 006.73⁵
02 1W
0001373153 DEC 01, 2015

**Ms. Jacqueline Trotta
Enforcement Analyst
Water Division/NPDES Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, AR 72118-5317**

7211885317 R01E

