

## Sanitary Sewer Overflow Monthly Report

Facility Name: City of Bentonville

Permit # AR0022403 Reporting period **March 1-31**

**2015**

**No Sanitary Sewer Overflows This Monitoring Period**

### Summary Report Code Descriptions

Cause(s) of SSO		SSO Impact	Action(s) Taken	Ultimate Discharge Location
C0-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact	WO-Work Order	CR-Creek/Stream/River
Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure/Break	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
Rainfall	RG-Roots & Grease		HR-Hand Rodded	GR-Ground Surface
RO-Roots	Vandalism		EN-Referenced to Engineer PN-Public Notification	PA-Paved Area CB-Contained in Building

Location	Manhole Number	Start Date of SSO	End Date of SSO	Estimated Volume in Gallons	Cause of SSO	Environmental Impact	Action(s) Taken to Address SSO	Ultimate Discharge Location
902 Convair		3/10/2015	3/10/2015	3,000	G,D	Neah	WO,EC,HC	PA
1706 S.E. Walton		3/14/2015	3/14/2015	132,000	Rainfall	Neah	EC	CR DI GR
1706 S.E. Walton		3/26/2015	3/27/2015	360,000	Rainfall	Neah	EC	CR DI GR

*Nancy Busen*

4-9-15

Signature of Cognizant or Ranking Official

Date

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."