

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality - Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0022560 Discharge Number 001
 Facility: Blytheville- West WWTP
 Address: P.O. Box 1784
 City: Blytheville State: AR Zip 72315
 Contact: Gary Carr Phone: 870-763-4961

Date of Non-Compliance	Parameter Exceeded	Quality or Loading	Quality or Concentration	Permit Limits
Aug 22	Dissolved Oxygen		1.1	7.0 MIN
Aug 22	NH3-N		13.5 - 13.7	2.8 - 4.5

We feel this problem was due to:

D.O. - Inadequate aeration, high water temperature and sludge buildup.
 NH3-N - Plant not operating properly due to excessive sludge build-up.


We plan on correcting the problem in this manner:

D.O. - New plant under construction.
 NH3-N - New plant under construction.

Time estimated that it will take to correct problem:

As soon as possible

Sincerely,


 Submitted By: _____

SEPTEMBER-8-2022
 Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)