

TELECON NOTE

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY

PERMIT No: AR0022560	AFIN: 47-00544	DATE & TIME: 2-27-19 1150 am
-------------------------	-------------------	---------------------------------

RE:

BETWEEN: Bob Stanley	OF: Blytheville West WWTP	PHONE: 870-763-4961
-------------------------	------------------------------	------------------------

AND:

Myrl V Lawrence Jr, Enforcement Analyst, ADEQ-OWQ-ENF

DISCUSSION:

Discussed NODI Code E submitted for Outfall TX1-Q Wet Testing during March, June, and September of 2018 and status of violations; Reviewed NetDMR values submitted and discussed non-compliance reports. Non-submittal issue was one of several issues caused by ~~lack of completion by previous operator and no notice departure of previous operator~~. No coordination was made with the laboratory to conduct WET testing. Discussed issues Mr. Stanley has been correcting since his arrival as new Class IV operator for the facility to resolve and prevent recurrence of violations.

ACTION ITEMS:

Conduct and submit WET testing results iaw the Permit