

Lawrence, Myrl

From: Lawrence, Myrl
Sent: Friday, August 24, 2018 11:33 AM
To: 'BWingfield@pmico.com'
Cc: 'gcarrblyww@gmail.com'; 'mayorsanders@sbcglobal.net'
Subject: AR0022560 Blytheville - West Facility



August 24, 2018

Brad Wingfield, P.E.
PMI
3512 S. Shackelford Rd.
Little Rock, AR 72205

RE: NPDES Permit Number AR0022560, AFIN 47-00544
Unachieved Final Compliance Date

Dear Mr. Wingfield,

As discussed by phone today, the final compliance date for the above named facility under CAO LIS 16-030 as amended by CAO LIS 16-030-001 was June 30, 2018. Failure to meet the final compliance date is a violation of the order.

A review of Discharge Monitoring Reports for the period August 1, 2017 through August 24, 2018 showed the following additional violations of the Permit:

DMR End Date	Discharge Number	Parameter Description	Reported DMR Value	Permit Limit	Vio %
01/31/2018	001-A	Nitrogen, ammonia total [as N] (MO AVG, lb/d)	51.7	38	36%
01/31/2018	001-A	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	7.8	3	160%
01/31/2018	001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	11.7	5	134%
03/31/2018	001-A	Nitrogen, ammonia total [as N] (MO AVG, lb/d)	55.5	38	46%
03/31/2018	001-A	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	4.6	3	53%
03/31/2018	001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	7	5	40%
04/30/2018	001-A	Nitrogen, ammonia total [as N] (MO AVG, lb/d)	37.2	35	6%
04/30/2018	001-A	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	4.2	2.8	50%
04/30/2018	001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	5.8	5	16%

04/30/2018	001-A	Coliform, fecal general (30DA GEO, #/100mL)	825	200	313%
04/30/2018	001-A	Coliform, fecal general (7 DA GEO, #/100mL)	993	400	148%
05/31/2018	001-A	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	3.3	2.8	18%
05/31/2018	001-A	Coliform, fecal general (30DA GEO, #/100mL)	730	200	265%
05/31/2018	001-A	Coliform, fecal general (7 DA GEO, #/100mL)	780	400	95%
06/30/2018	001-A	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	5.8	2.8	107%
06/30/2018	001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	8.4	5	68%
06/30/2018	001-A	Coliform, fecal general (30DA GEO, #/100mL)	546	200	173%
06/30/2018	001-A	Coliform, fecal general (7 DA GEO, #/100mL)	605	400	51%

Additionally, the Department has been notified that no sampling was conducted during the month of July. Failure to sample is also a violation of the Permit.

Please consult with the facility during your next contact to develop a course of action to revise the corrective action plan (CAP) and milestone schedule to bring the facility into compliance with the Permit. A request for revision of the final compliance date, milestone schedule, and subsequent final compliance extension of CAO LIS 16-030 as amended by CAO LIS 16-030-001, should be submitted under the Mayor's signature as soon as possible. The request should also include a brief explanation of why the compliance date wasn't met and an outline of actions currently being taken or planned to resolve the violations and prevent future occurrences.

Your assistance in this matter is most appreciated. Should you have questions or desire assistance please contact me at 501-682-0699 or by reply to myrl.lawrence@adeq.state.ar.us.

Sincerely,



Myrl V Lawrence Jr
 Enforcement Analyst
 ADEQ Office of Water Quality

Cc: Gary Carr, Facility Director, City of Blytheville, gcarrblyww@gmail.com
 James Sanders, Mayor, City of Blytheville, mayorsanders@sbcglobal.net

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
 5301 NORTHSHORE DRIVE / NORTH LITTLE ROCK / ARKANSAS 72118-5317
 TELEPHONE 501-682-0744 / FAX 501-682-0880 / www.adeq.state.ar.us