

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0022560 Discharge Number: 001

Facility: Blytheville - West WWTP

Address: P.O. Box 1784

City: Blytheville State: AR. Zip: 72315

Contact: Gary Carr Phone: 870-763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
Nov. 2020	NH ₃		12.3/17.4	3/4.5

We feel this problem was due to:

Sludge build-up and plant inability to keep sludge mixed due to the build-up. Polishing pond also being full of sludge.

We plan on correcting the problem in this manner:

Trying to eliminate sludge build up and we are meeting with engineers today to discuss plans.

Time estimated that it will take to correct problem:

Plan to correct problem as soon as sludge can be removed and other plans put into effect.

Sincerely,

Gary Carr

Submitted By:

December 16, 2020

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)