

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118


RE: Permit No: AR0022560 Discharge Number: 001
 Facility: Blytheville- West WWTP
 Address: P.O. Box 1784
 City: Blytheville State: AR Zip: 72315
 Contact: Gary Carr Phone: 870-763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
Jan 2021	NH3		13.1/14.7	3/4.5
	Mercury		0.0761/0.0761	0.0328/0.0657

We feel this problem was due to:
NH3 due to excess sludge in plant and polishing pond. Mercury not sure for spike.

We plan on correcting the problem in this manner:
New plant will replace this plant. Mercury spike is being looked at to see if some business has started in surrounding area for possible source.

Time estimated that it will take to correct problem:
NH3 should be corrected with the new plant. Mercury as soon as we can determine source.

Sincerely,

 Submitted By: _____

2-24-2021
 Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)