

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0022560 Discharge Number: 001

Facility: Blytheville - West WWTP

Address: P.O. Box 1784

City: Blytheville State: AR Zip: 72315

Contact: Gary Carr Phone: 870-763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
August 2020	fecal		521/1971	200/400
	NH ₃	13.2	13.2/15.0	2.8/4.5

We feel this problem was due to:

WWTP full of sludge and polishing pond full of sludge. Many mechanical problems due to age. UV lights electrical problems.

We plan on correcting the problem in this manner:

Building new WWTP and doing away with this plant.

Time estimated that it will take to correct problem:

ASAP. New plant work has begun.

Sincerely,



Submitted By:

SEPTEMBER 23 2020

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)