

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0022560 Discharge Number: 001

Facility: Blytheville - West WWTP

Address: P.O. Box 1784

City: Blytheville State: AR Zip: 72315

Contact: Gary Carr Phone: 870-763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
Sept. 2020	NH ₃	10.8	10.8/16.9	2.8/4.5
	fecal		2833/4133	200/400

We feel this problem was due to:

NH₃ due to failure of WWTP and sludge build-up in plant and polishing pond
Fecal not being reduced due to UV lights.


We plan on correcting the problem in this manner:


New WWTP that is being built will solve both problems. We expect and are seeing better fecal numbers since we started cleaning UV lights everyday.

Time estimated that it will take to correct problem:

As soon as new WWTP is completed.

Sincerely,


Submitted By:


Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)