

## NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 Office of Water Quality – Enforcement Branch  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: Permit No: AR0022560 Discharge Number: 001  
 Facility: Blytheville- West WWTP  
 Address: P.O. Box 1784  
 City: Blytheville State: AR Zip: 72315  
 Contact: Gary Carr Phone: 870-763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
Dec. 2020	NH <sub>3</sub>	38.8	15/16	38/3/4.5

We feel this problem was due to:

Plant & Polishing Pond full of sludge and no treatment and mixing of mix liquid due to build up.

We plan on correcting the problem in this manner:

Construction of new plant has begun and ~~and~~ when built will eliminate problems we now face. We have changed our UV cleaning procedures and has help greatly on fecal NCP.

Time estimated that it will take to correct problem:

hopefully this year.

Sincerely,

Gary Carr  
 Submitted By:

JANUARY 20-2021  
 Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)