

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022560 Discharge Number: 001
Facility: Blytheville-West WWTP
Address: P.O. BOX 1784
City: Blytheville State: AR Zip: 72315
Contact: Gary Carr Phone: 870-763-4961

| Date of Non-Compliance | Parameter Exceeded | Quantity or Loading | Quality or Concentration | Permit Limits |
|------------------------|-------------------------|---------------------|--------------------------|-------------------------------|
| <u>Jan 2019</u> | <u>NH₃-N</u> | <u>47.7</u> | <u>6.3/8.4</u> | <u>350/2.8/4.5</u> |
| | | | | |
| | | | | |

We feel this problem was due to:

High Flows

We plan on correcting the problem in this manner:

Engineer is working on Solution

Time estimated that it will take to correct problem:

As soon as possible.

Sincerely,

Gary Carr

Authorized Signature

FEB-20-2019

Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)