

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 Office of Water Quality – Enforcement Branch  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: Permit No: AR0022560 Discharge Number: 001

Facility: Blytheville - West WWTP

Address: P.O. Box 1784

City: Blytheville State: AR Zip: 72315

Contact: Gary Carr Phone: 870-763-4961


Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
May 2020	NH <sub>3</sub> fecal	71.4	9.2/12.1 1065/2310	35/2.8/4.5 200/400

We feel this problem was due to:  
 NH<sub>3</sub> due to plant failure and sludge accumulation.  
 fecal due to UV light panel failure.

We plan on correcting the problem in this manner:  
 NH<sub>3</sub> compliance could only be achieved by dredging basin, polishing tank as well as Rehab of plant.  
 fecal should not be problem if UV is working and system is clean.

Time estimated that it will take to correct problem:  
 UV light panel has been replaced and Bids are being finalized to begin building new plant.

Sincerely,



JUNE 23-2020

Submitted By:

Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)