

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 Office of Water Quality – Enforcement Branch  
 5301 Northshore Drive  
 North Little Rock, AR 72118


RE: Permit No: AR0022560 Discharge Number: 001  
 Facility: Blytheville- West WWTP  
 Address: P.O. Box 1784  
 City: Blytheville State: AR Zip: 72315  
 Contact: Gary Carr Phone: 870-763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
MAY 2021	NH <sub>3</sub>	92	12.5/14.8	35/2.8/4.5

We feel this problem was due to:  
Sludge build-up in plant & Blishing Pond.

We plan on correcting the problem in this manner:  
New plant is being built to replace existing plant and old plants will be dredged out and used as stormwater overflow basins.

Time estimated that it will take to correct problem:  
As soon as new plant can be completed.

Sincerely,  
  
 Submitted By:

JUNE-08-2021  
 Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)