

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0022560 Discharge Number: 001

Facility: Blytheville - West WWTP

Address: P.O. Box 1784

City: Blytheville State: AR. Zip: 72315

Contact: Gary Carr Phone: 870-763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
Oct. 2020	NH ₃	49.1	15.7/17.4	35/2.8/4.5
	fecal/7 day/ave		2812	2000

We feel this problem was due to:

NH₃ excursion due to plant failure and sludge buildup
fecal excursion was at first of month and orders were set in place
for UV lights to be cleaned every week and last three weeks
fecal was very low and in permit

We plan on correcting the problem in this manner:

NH₃ excursion will be corrected by the new plant
that is being built, and operators cleaning the UV lights
every week will solve fecal problem.


Time estimated that it will take to correct problem:

Groundwork for new plant is almost complete
and pipe & equipment and other construction supplies are being
ordered.

Sincerely,



Submitted By:



Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)