

# ADEQ

ARKANSAS  
Department of Environmental Quality

August 4, 2011

City of Blytheville, West WWTF  
Attention: James Yankee  
P.O. Box 1784  
Blytheville, AR 72316

RE: NPDES Permit Number AR0022560, AFIN 47-00544

Dear Mr. Yankee:

A recent review of the NPDES file for **City of Blytheville - WWTP** has revealed the following violations for the monitoring period ending **05/31/2011**.

DISCHARGE NUMBER	PARAMETER	VIOLATION	LIMIT	UNITS
001-A	Fecal General Coliform	667	200 30 Day Avg.	#/100mL
001-A	Fecal General Coliform	1146	400 7 Day Avg.	#/100mL
001-A	NH3-N	50.0	38	lb/d
001-A	NH3-N	6.2	3	mg/L
001-A	NH3-N	7.9	5	mg/L

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit require you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Please refer to NPDES Permit Number **AR0022560** and AFIN **47-00544** in any written correspondence to ADEQ. Should you have any questions, feel free to call 501-682-0631 or e-mail [meints@adeq.state.ar.us](mailto:meints@adeq.state.ar.us).

Sincerely,



René E. Meints  
Enforcement Analyst - Water Division Enforcement Branch