

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR00225 Discharge Number: 001
Facility: Blytheville-West WWTP
Address: P.O. BOX 1784
City: Blytheville State: AR Zip: 72315
Contact: Gary Carr Phone: 870-763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>Dec. 2018</u>	<u>NH-3-N</u>		<u>4.5/5.2</u>	<u>3 / 4.5</u>

We feel this problem was due to:

Return sludge not being mixed with influent and
short circuiting

We plan on correcting the problem in this manner:

See if engineer can determine a way to get mixing
and stop short circuiting

Time estimated that it will take to correct problem:

test next few weeks will determine fix

Sincerely,

Gary Carr
Authorized Signature

JAN 16 2019
Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)