

Lawrence, Myrl

From: Lawrence, Myrl
Sent: Monday, June 17, 2019 10:14 AM
To: 'gcarrblyww@gmail.com'
Subject: Effluent Violations Letter



June 17, 2019

Honorable James Sanders
Mayor, City of Blytheville
P.O. Box 1784
Blytheville, AR 72316

**RE: NPDES Permit Number AR0022560– West, AFIN 47-00544
Effluent Limit Violations**

Dear Mayor Sanders:

A review of the Permit file for the above mentioned facility for the period of July 1, 2018 through June 17, 2019 reveals the following compliance issues:

The following **26 effluent violations** of Part I, Section A of Permit No. **AR0022560** were reported:


Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio	Violation Code	Parameter Code
04/30/2019	001-A	Nitrogen, ammonia total [as N], MO AVG, lb/d	35	45.8	31%	E90	00610-1-0
04/30/2019	001-A	Nitrogen, ammonia total [as N], MO AVG, mg/L	2.8	8	186%	E90	00610-1-0
04/30/2019	001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	5	14	180%	E90	00610-1-0
04/30/2019	001-A	Mercury, total recoverable, MO AVG, ug/L	0.0328	<u>0.0881</u>	169%	E90	71901-1-0
04/30/2019	001-A	Mercury, total recoverable, 7 DA AVG, ug/L	0.0657	<u>0.0881</u>	34%	E90	71901-1-0
04/30/2019	001-A	Coliform, fecal general, 30DA GEO, #/100mL	200	319	60%	E90	74055-1-0
04/30/2019	001-A	Coliform, fecal general, 7 DA GEO, #/100mL	400	1525	281%	E90	74055-1-0
03/31/2019	001-A	Nitrogen, ammonia total [as N], MO	38	58	53%	E90	00610-1-1

		AVG, lb/d					
03/31/2019	001-A	Nitrogen, ammonia total [as N], MO AVG, mg/L	3	7.6	153%	E90	00610-1-1
03/31/2019	001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	5	9.6	92%	E90	00610-1-1
02/28/2019	001-A	Nitrogen, ammonia total [as N], MO AVG, lb/d	38	72.4	91%	E90	00610-1-1
02/28/2019	001-A	Nitrogen, ammonia total [as N], MO AVG, mg/L	3	4.6	53%	E90	00610-1-1
02/28/2019	001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	5	9.3	86%	E90	00610-1-1
02/28/2019	001-A	Coliform, fecal general, 30DA GEO, #/100mL	1000	1384	38%	E90	74055-1-1
02/28/2019	001-A	Coliform, fecal general, 7 DA GEO, #/100mL	2000	5446	172%	E90	74055-1-1
01/31/2019	001-A	Nitrogen, ammonia total [as N], MO AVG, lb/d	38	47.7	26%	E90	00610-1-1
01/31/2019	001-A	Nitrogen, ammonia total [as N], MO AVG, mg/L	3	6.3	110%	E90	00610-1-1
01/31/2019	001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	5	8.4	68%	E90	00610-1-1
12/31/2018	001-A	Nitrogen, ammonia total [as N], MO AVG, mg/L	3	4.5	50%	E90	00610-1-1
12/31/2018	001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	5	5.2	4%	E90	00610-1-1
11/30/2018	001-A	Nitrogen, ammonia total [as N], MO AVG, mg/L	3	4	33%	E90	00610-1-1
11/30/2018	001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	5	5.7	14%	E90	00610-1-1
09/30/2018	001-A	Coliform, fecal general, 30DA GEO, #/100mL	200	1281	541%	E90	74055-1-0
09/30/2018	001-A	Coliform, fecal general, 7 DA GEO, #/100mL	400	1756	339%	E90	74055-1-0
08/31/2018	001-A	Coliform, fecal general, 30DA GEO, #/100mL	200	698	249%	E90	74055-1-0
08/31/2018	001-A	Coliform, fecal general, 7 DA GEO, #/100mL	400	1462	266%	E90	74055-1-0

Non-compliance reports with corrective actions were received by the Department. Any violation of your Permit is subject to further enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0699, or you may e-mail me at myrl.lawrence@adeq.state.ar.us.

Sincerely,



Myrl V Lawrence Jr
Enforcement Analyst
ADEQ Office of Water Quality
Phone: 501-682-0699



cc: Gary Carr, Wastewater Superintendent, City of Blytheville, gcarrblyww@gmail.com