

ADEQ

ARKANSAS
Department of Environmental Quality

April 18, 2012

Mr. James Yankee
City of Blytheville West Wastewater Treatment Facility
P.O. Box 1784
Blytheville AR 72316

RE: NPDES Permit No. AR0022560, AFIN 47-00544

Dear Mr. Yankee:

A review of the NPDES file for the aforementioned facility for the monitoring period ending December 31, 2011 revealed that the facility reported violations of Part I, Section A. of NPDES Permit No.: AR0022560. The effluent violations reported on the DMRs are as follows:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
12/31/2011	001-A	Solids, total suspended, MO AVG, lb/d	891.7	375
12/31/2011	001-A	Solids, total suspended, 7 DA AVG, mg/L	89.7	45
12/31/2011	001-A	Nitrogen, ammonia total (as N), 7 DA AVG, mg/L	6.3	5

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0631, or you may e-mail me at johnsonm@adeq.state.ar.us.

Sincerely,



Miles Johnson
Enforcement Analyst
Water Division / Enforcement Branch