

# WEST

## NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality - Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: AR0022560 Discharge Number 001  
Facility: Blytheville- West WWTP  
Address: P.O. Box 1784  
City: Blytheville State: AR Zip 72315  
Contact: Gary Carr Phone: 870-763-4961

Date of Non-Compliance	Parameter Exceeded	Quality or Loading	Quality or Concentration	Permit Limits
Jun-22	Dissolved Oxygen		4.4	7.0 MIN
Jun-22	NH3-N		14.7 - 17.1	2.8 - 4.5

**We feel this problem was due to:**

D.O. - Inadequate aeration, high water temperature and sludge buildup.

NH3-N - Plant not operating properly due to excessive sludge build-up.

**We plan on correcting the problem in this manner:**

D.O. - New plant under construction.

NH3-N - New plant under construction.

**Time estimated that it will take to correct problem:**

As soon as possible

Sincerely,

  
Submitted By

July-12-2022  
Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)