

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0022560 Discharge Number: 001
Facility: Blytheville- West WWTP
Address: P.O. Box 1784
City: Blytheville State: AR Zip: 72315
Contact: Gary Carr Phone: 870-763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
April 2022	Dissolved Oxygen		3.8	7.0
April 2022	NH3-N	77.5	9.3 - 11.6	35.0 - 2.8 - 4.5
April 2022	Fecal		618 -1134	200 -- 400

We feel this problem was due to:

Field D.O. unit Operator error
NH3-N plant failure due to excess sludge
Fecal - Proper maintenance was not adhered to. Operator error

We plan on correcting the problem in this manner:

Dissolved Oxygen, checked menu for proper settings and made proper adjustments.
NH3-N, plant failure due to excess sludge.
Fecals, Stress the the importance of proper maintenance

Time estimated that it will take to correct problem:

NH3-N will be addressed as soon as new plant is up and going. Fecals and D.O. will be addressed immediately.

Sincerely,


Submitted By: _____


Date _____

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)