

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0022560 Discharge Number: 001

Facility: Blytheville- West WWTP

Address: P.O. Box 1784

City: Blytheville State: AR Zip: 72315

Contact: Gary Carr Phone: 870-763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
March 2022	NH3-N	53.4	13 15	38.0 - 3.0 - 4.5
March 2022	D.O.		5.8	7.0

We feel this problem was due to:

NH3-N is due to plant failure because of sludge build up.
D.O. reading was out due to Operator error. Parameters were skewed due do improper setting being applied. Reading was taken over the weekend and caught the errors Monday Morning. All DO's for the month were good other these outliers


We plan on correcting the problem in this manner:

NH3-N were building a new plant. For the D.O meter we're Stressing that the operators use the reference manual to make parameter changes.

Time estimated that it will take to correct problem:

As soon as possible.

Sincerely,


Submitted By: _____

APRIL-05-2022
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)