

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality – Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: AR0022560 Discharge Number: 001

Facility: Blytheville- West WWTP

Address: P.O. Box 1784

City: Blytheville State: AR Zip: 72315

Contact: Gary Carr Phone: 870-763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
10-2021	Dissolved Oxygen		5.0	7.0
10-2021	Ammonia		15.1-16.3	3-4.5

We feel this problem was due to:

Unknown on D.O. the last week it was 7.0 or above. Ammonia is due to plant failure from sludge build up


We plan on correcting the problem in this manner:

Building new plant

Time estimated that it will take to correct problem:

D.O. appears to be staying above 7.0 and new plant will solve the ammonia problem.

Sincerely,

  
Submitted By:

November-9-2021  
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)