

PERMIT LETTER



PERMIT INFORMATION

PERMIT NAME: Blytheville W. Treatment Plant

PERMIT #: AR0022560

PERMIT LINK: _____

<https://www.adeg.state.ar.us/downloads/WebDatabases/PermitsOnline/NPDES/IssuedPermits/ar002256>



PERMIT EXPIRATION

PERMIT EXPIRES: 3/31/28

RENEWAL APPLICATION DUE DATE: 10/1/27



REPORTS

CAO/CAP COMPLIANCE SCHEDULE: CAO LIS 20-166 Quarterly Progress Reports

PERMIT COMPLIANCE SCHEDULE: Refer to permit Section B. Permit Compliance Schedule on Page 1 of Part 1.B for details.



DISCHARGE MONITORING REPORT (DMR)

DMRs are due on the 25th of the month. A Cognizant or Responsible Official must have a CDX/NetDMR account to submit DMRs. If there are effluent violations, a Non-Compliance Report (NCR) must be attached to the DMR via NetDMR.



OPERATOR

My treatment plant requires a Class III Operator licensed in the State of Arkansas.



CONTACT ASSISTANCE

NAME: Tiana Toups

TITLE: Enforcement Analyst

PHONE NUMBER: 501-682-0699

EMAIL: tiana.toups@adeq.state.ar.us



ENVIRONMENTAL
QUALITY

AR0022560

SIGNIFICANT CHANGES FROM THE PREVIOUSLY ISSUED PERMIT

The permittee is responsible for carefully reading the permit in detail and becoming familiar with all of the changes therein:

1. The mailing address was removed from the cover page.
2. The description of the receiving stream was updated to include Pemiscot Bayou.
3. The CBOD5 concentration limit and mass limits for CBOD5, TSS, NH3-N, and Copper were updated due to a change in rounding procedures.
4. The FCB limits for April were revised. See Section 12.A of this Fact Sheet for additional information.
5. The monitoring frequency for Total Phosphorus (TP) and Nitrate + Nitrite Nitrogen (NO3 + NO2 – N) was reduced to once per quarter in Part I.A. See Section 12.A of this Fact Sheet for additional information.
6. The monitoring requirement for Arsenic and minimum quantification level condition in Part II.9 of the previous permit was removed. See Section 12.E of this Fact Sheet for additional information.
7. The pretreatment report was removed from Part I.A since it was incorporated in Part II.7.
8. The Copper and Mercury limits were updated. See Section 12.A and 12.E of this Fact Sheet for additional information.
9. New WET lethal and sub-lethal limits for *P. promelas* and *C. dubia* were included in the permit. See Section 13 of this Fact Sheet for further information.
10. The requirements to measure sludge in the sludge lagoon and develop to remove the sludge were included in the Part I.B of the permit.
11. The requirement to monitor the influent CBOD5 and TSS was removed from Part II.2 of the permit.
12. The Sanitary Sewer Overflow (SSO) condition was revised in Part II.5 of the permit.

13. The sludge disposal condition in Part II.8 of the previous permit was removed. Sludge disposal is addressed in Part III.B.6 of the permit.
14. A monitoring frequency reduction condition was included in Part II.10 of the permit.
15. Part III.C.5 of the permit now requires that DMRs be submitted electronically via NetDMR.
16. The twenty-four hour reporting condition was revised in Part III.D.6 of the permit.
17. The discharge of toxic substances condition was revised in Part III.D.8 of the permit.

Karren Thomas (adpce.ad)

From: Karren Thomas (adpce.ad)
Sent: Tuesday, May 9, 2023 12:12 PM
To: 'mlogan@cityofblytheville.com'
Cc: 'gcarrblyww@gmail.com'; Tiana Toups (adpce.ad)
Subject: AR0022560 Permit Letter
Attachments: AR0022560_Permit Sheet_20230509.pdf; AR0022560 Significcant Changes Form.pdf

Good morning Mayor Logan,

Attached above is a Permit Letter that highlights information about your recently issued permit that became effective April 1, 2023.

Also included is a list of Significant Changes from the previously issued permit. (Permittee is responsible for carefully reading the permit in detail and becoming familiar with **ALL** the changes.)

If you have any questions, please call or e-mail the contact listed at the bottom of the Permit Letter.

Karren Thomas | Wastewater Licensing Extra Help
**Division of Environmental Quality | Office of Water Quality
Enforcement Section**
5301 Northshore Drive | North Little Rock, AR 72118
t: 501.682.0608 | f: 501.682.0880 | e: WWL@adeq.state.ar.us



ARKANSAS
ENERGY & ENVIRONMENT

Cc: Gary W. Carr, Director
Cc: Tiana Toups, Enforcement Analyst (tiana.toups@adeq.state.ar.us)