

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 NPDES Enforcement Section  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0022560 Discharge Number: 001  
 Facility: Blytheville - West WWTP  
 Address: P.O. Box 1784  
 City: Blytheville State: AR Zip: 72315  
 Contact: Gary Carr Phone: 870-763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>April 2019</u>	<u>Mercury</u>		<u>0.0881 / 0.0881</u>	<u>0.0325 / 0.0657</u>

**We feel this problem was due to:**

unknown! we had testing facility to check for errors and they said results were right. Levels have been ok all year until this sample.

**We plan on correcting the problem in this manner:**

We discussed dumping and are checking to see if UV lights at the water plant contain mercury. we did have turtle to break some.

**Time estimated that it will take to correct problem:**

we hope the problem is fix-

Sincerely,

  
 Authorized Signature

5/15/2019  
 Date

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)