

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022560 Discharge Number: 001

Facility: Blytheville - West WWTP

Address: P.O. Box 1784

City: Blytheville State: AR Zip: 72315

Contact: Gary Carr Phone: 870-763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>Oct. 2019</u>	<u>NH₃</u>		<u>5.0/9.4</u>	<u>2.8/5.0</u>

We feel this problem was due to:
Sludge Buildup and inadequate Treatment
Plant mechanical failures -

We plan on correcting the problem in this manner:
Building new WWTP.

Time estimated that it will take to correct problem:
ASAP.

Sincerely,
Gary Carr
Authorized Signature

NOVEMBER 06-2019
Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)