

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0022560 Discharge Number: 001
 Facility: Blytheville-West WWTP
 Address: P.O. BOX 1784
 City: Blytheville State: AR Zip: 72315
 Contact: Gary Carr Phone: 870-763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
Sept 2019	NH ₃ fecal		17.4 / 19.6 1001 / 1638	2.8 / 5 200 / 400

We feel this problem was due to:
Plant and Polishing Pond full of sludge and fecal due to broken butts in UV React

We plan on correcting the problem in this manner:
New Plant Being Built.

Time estimated that it will take to correct problem:
ASAP.

Sincerely,


 Authorized Signature

Oct. 9, 2019

 Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)