



May 31, 2018

Gavin Gray
Arkansas Department of Environmental Quality
Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118-5317

RE: City of Blytheville – West Wastewater Treatment Plant
NPDES Permit No. AR0022560 AFIN: 47-00544
Consent Administrative Order LIS16-030

Dear Mr. Gray:

This letter is intended to serve as the June 2018 compliance report for CAO LIS 16-030 for the City of Blytheville's West Wastewater Treatment Plant. A review of the facility's Discharge Monitoring Reports was conducted from February 1, 2018 through April 30, 2018. During this time period, six exceedances were noted for Ammonia, Nitrogen and two exceedances were noted for Fecal Coliforms. No exceedances for Mercury occurred during this time period.

As per the corrective action plan, Mercury has been controlled using proper sampling techniques, and no violations have occurred since April 30th, 2016. Alkalinity has been tested and levels have not been adequate to ensure complete nitrification of ammonia. Additional testing is underway and chemical feed options are being evaluated. The UV system manufacturer has been contacted to determine the cause of the Fecal Coliforms. All aspects of the system are being maintained and appear to be functioning as designed.

Should you have any questions or require additional information, please do not hesitate to contact me at 501-221-7122 or bwingfield@pmico.com.

Sincerely,

PMI

Brad Wingfield, P.E.
Principal – Engineering Division