



February 28, 2018

Gavin Gray
Arkansas Department of Environmental Quality
Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118-5317

RE: City of Blytheville – West Wastewater Treatment Plant
NPDES Permit No. AR0022560 AFIN: 47-00544
Consent Administrative Order LIS16-030

Dear Mr. Gray:

This letter is intended to serve as the compliance report for CAO LIS 16-030 for the City of Blytheville's West Wastewater Treatment Plant. A review of the facility's Discharge Monitoring Reports was conducted from October 2, 2017 through February 28, 2018. No exceedances were observed for any parameters during this time.

As per the corrective action plan, Mercury has been controlled using proper sampling techniques, and no violations have occurred since April 30th, 2016. Alkalinity guidelines have been established to ensure that Ammonia is adequately nitrified.

Should you have any questions or require additional information, please do not hesitate to contact me at 501-221-7122 or bwingfield@pmico.com.

Sincerely,

PMI

Brad Wingfield, P.E.
Principal – Engineering Division